



Bruhath Bangalore Mahanagara Palike

Medical Officer of Health
Kengeri Division, Bangalore.

No. 39/24-25

Date:- 05-02-2024

PERFORMA REGARDING NOC & SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

This is to certify that an inspection team headed by Mr. Dr. Vevekananda, Medical Officer of health (Name of Officers with designation) from BBMP Health Department (Name of Department/Office) inspected the **South Asian Central Academy** Andrahalli Vishwaneedam Post Bangalore-560091. (Name & address of the school) on 05-02-2024 and found that the **South Asian Central Academy** (Name Of School) has safe drinking water facilities for the students and members of staff of the institution and in maintain the hygienic sanitation condition in the school bulding & the campus as per the norms prescribed by the central/state/U.T.Govt.

The above NOC is valid for the Period of up to 31-03-2025

Dr. Vivekananda

ಆರೋಗ್ಯವೈದ್ಯಾಧಿಕಾರಿ
Medical Officer of Health
Rajarajeshwari Nagar, Zone
Kengeri Division
Bruhath Bangalore Mahanagara Palike

To
South Asian Central Academy
Andrahalli Vishwaneedam Post,
Bangalore-560091.

For South Asian Central Academy

[Signature]
Manager

For South Asian Central Academy

[Signature]
Principal

GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/ 943/23-24

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated: 13/02/2024

Report of Bacteriological analysis of Water/Effluent sample

| Sample No. | Source & Particulars of Water Sample | Opinion | | | | |
|------------|--------------------------------------|-------------|-------------|----------|-------|---------------|
| | | M.P.N Count | Plate Count | D.C Test | S.P.P | N.S.P.P & FC. |
| 2991 | Bore well | Nil | - | - | SPP | - |

South Asian Central School,
Andaraballi
Bengaluru - 91

Note:
M.P.N Count:
Most probable number of Bacteria per 100ml of Water
D.C Test:
Differential Colliform test
Plate Count:
Plate Count per ml of sample
SPP:
Water is satisfactory for Potable purpose
NSPP:
Water is not satisfactory for Drinking purpose
NSPP & FC:
Water is not satisfactory for Drinking purpose and E.Coli found

For South Asian Central Academy
For South Asian Central Academy
Manager
Principal
For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru
(PTO)

Advice:

1. Sample.....
Need effective chlorination before use
2. Sample.....

Need to avoid possible source of fecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WAPPPTER

| | | Presumptive Coliform count per 100ml | E coli count per 100 ml |
|---------|----------------|--|-------------------------------|
| CLASS 1 | Excellent | 0 | 0 |
| CLASS 2 | Satisfactory | 1-3 | 0 |
| CLASS 3 | Suspicious | 4-10 | 0 |
| CLASS 4 | Unsatisfactory | Greater than 10 | 0.1 or More |

For South Asian Central Academy

Ranjana
Manager

For South Asian Central Academy

Ranjana
Principal